



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on April 12, 2017.

AES Arabia Ltd.
Jarir Street Al Malaz
P.O. Box 105689
Riyadh 11656
Saudi Arabia
966 1 1477 2398

Facility: # 1 Saudi Arabia

Chemical/ Trade Designation	Function	Max Use	
Miscellaneous Chemical Products			
Desalcure-A-400	Reverse Osmosis Antiscalant	10	mg/L
Miscellaneous Treatment Chemical			
AES-A-5082	pH Adjustment	40	mg/L
Desalcure-CN-440 [1]	Dechlorination	40	mg/L
Miscellaneous Water Supply Products			
AES-BI-5081 [CL]	Bactericide	13	mg/L
	Disinfection & Oxidation		
AES-MS-100	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
AES-MS-120	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-200	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-3050	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-200	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-2010	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-2020	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-300	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-3010	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-3020	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-3030	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-3040	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.



Desalcure-A-3050	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Desalcure-A-800	Distillation Antiscalant	10	mg/L
	Reverse Osmosis Antiscalant		
Zinc Orthophosphate [CL] [ZN]			
AES-PC-128	Corrosion & Scale Control	26	mg/L

[1] This product contains sulfite. Sulfites have been known to cause potentially lethal allergic reactions in sulfite-sensitive individuals. The maximum recommended allowable residual sulfite level in the finished drinking water is 100 ppb (0.1 mg/L).

[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

[ZN] Based on an evaluation of health effects data, the level of zinc in the finished drinking water shall not exceed 2.0 mg/L.